

Certificate Reference: **DEMSE 6633**

1 DETAILS OF THE CLIENT
 Client Address: **Robertsons Construction, Level 4 West Tower Baltic Place, South Shore Road, Gateshead, NE83AE**

2 DETAILS OF THE INSTALLATION
 Installation Address: **Clavering Place, Newcastle Upon Tyne, NE1 3NG**
 Extent of the installation covered by this certificate: 100% of the installation. Heights of some Distribution Boards do not comply with Building Regs Approved Document P, which states that the circuit protective device should be installed at a accessible height between 1350mm & 1450mm from finished floor level. height specified by Robertsons Construction. Items 8.4 & 11.3 on the Inspection Check list are marked as code 3 as some distribution boards are made of plastic and does not comply to BS7671- Not all Circuits Protected by 30 Ma Rcd does not comply to BS7671- Items supplied and specified by Robertsons Construction
 The installation is: **New installation** **Addition to an existing installation** **N/A** **Alteration to an existing installation** **N/A**

3 DESIGN
 I/We being the person(s) responsible for the design of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, hereby CERTIFY that the design work for which I/we have been responsible is to the best of my/our knowledge and belief in accordance with BS 7671:2008, amended to 2015 except for the departures, if any, detailed as follows.
 Details of departures from BS 7671 (Regulations 120.3, 133.5): **See Extent of this instalation covered by this certificate**
 Details of permitted exceptions (Regulations 411.3.3): **Risk assessment attached** **N/A**
 -
 The extent of liability of the signatory/signatories is limited to the work described above as the subject of this certificate.
 For the DESIGN of the installation:
 Name: **-** Position: **-** Signature: **-** Date: **22/06/2016**
 Where there is divided responsibility for the design:
 Name: **-** Position: **-** Signature: **-** Date: **22/06/2016**

4 CONSTRUCTION
 I/We being the person(s) responsible for the construction of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the construction, hereby CERTIFY that the construction work for which I/we have been responsible is to the best of my/our knowledge and belief in accordance with BS 7671:2008, amended to 2015 except for the departures, if any, detailed as follows.
 Details of departures from BS 7671 (Regulations 120.3, 133.5): **See Extent of this instalation covered by this certificate**
 The extent of liability of the signatory/signatories is limited to the work described above as the subject of this certificate.
 For the CONSTRUCTION of the installation:
 Name: **David Wade** Position: **Qualified Supervisor** Signature: *David Wade* Date: **22/06/2016**

5 INSPECTION AND TESTING
 I/We being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby CERTIFY that the inspection and testing work for which I/we have been responsible is to the best of my/our knowledge and belief in accordance with BS 7671:2008, amended to 2015 except for the departures, if any, detailed as follows.
 Details of departures from BS 7671 (Regulations 120.3, 133.5): **See Extent of the installation covered by this**
 The extent of liability of the signatory/signatories is limited to the work described above as the subject of this certificate.
 For the INSPECTION AND TESTING of the installation:
 Name: **Stephen Tutty** Position: **Electrician** Signature: *Stephen Tutty* Date: **22/06/2016**
 Report reviewed and confirmed by:
 Name: **Paul Holmes** Position: **Qualified Supervisor** Signature: *Paul Holmes* Date: **22/06/2016**

6 DESIGN, CONSTRUCTION, INSPECTION AND TESTING
 I/We being the person(s) responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the design work for which I/we have been responsible is to the best of my/our knowledge and belief in accordance with BS 7671:2008, amended to 2015 except for the departures, if any, detailed as follows.
 Details of departures from BS 7671 (Regulations 120.3, 133.5): **None**
 The extent of liability of the signatory/signatories is limited to the work described above as the subject of this certificate.
 For the DESIGN, the CONSTRUCTION, and the INSPECTION AND TESTING of the installation:
 Name: **NA** Position: **NA** Signature: **-** Date: **22/06/2016**
 Report reviewed and confirmed by:
 Name: **NA** Position: **NA** Signature: **-** Date: **22/06/2016**

7 NEXT INSPECTION
 I/We the designer(s), RECOMMEND that this installation is further inspected and tested after an interval of not more than: **5 Years**